



Sales, Service & Manufacturing

302 Mill Street, PO Box 307, Buda, Illinois 61314

Phone: 309-895-2311 / Toll Free: 888-877-8225 / Fax: 309-895-3891

Web Site: www.vpstack.com / Email: vptech@vpstack.com

MODEL CS

UL 1738 Venting Systems for Gas-Burning Appliances, Categories II, III, and IV



The Model CS venting system is fabricated from material unyielding, dependable, and resistant to heat.

- standard UL 1738 tested and listed
- double wall construction with a one-inch air gap
- liner: 24 gauge type VP1738 stainless steel
- shell: 24 gauge aluminized steel (other options available upon request)
- flanged liner connection; vee band
- shell connection; draw band
- silicone sealant for flanged liner connections

Van-Packer has been working with metallurgists and steel manufactures to find a material with better workability and weld ability, than the AL29-4C currently used in the condensing and near condensing chimneys and yet maintain the corrosion resistance required by these applications and the severe testing requirements of UL Standard 1738. Our Model CS is the result of this research and testing. Model CS is designed to vent Category II, III, and IV heating systems and is fabricated with the same-rugged flange-to-flange connections as our Model DW Building Heating Appliance Chimney. Available in sizes from 4"ID to 24"ID CS is listed for applications to 550F and pressures to 5-inch water column with a 2-inch clearance to combustibles.